



**ROSEBURG FIRE DEPARTMENT
FIRE PREVENTION DIVISION**

fireprevention@cityofroseburg.org

700 SE Douglas Avenue
Roseburg, OR 97470
Phone (541) 492-6770

**Commerical Cooking Operations
Final Inspection Checklist**

Douglas County Permit No: _____

Occupancy Name: _____

Address: _____

Contact Name/Signature _____

Inspector: _____

Date: _____

All Surfaces Protected Yes / No _____

Plenum Protected Yes / No _____

Duct Protected Yes / No _____

Manual Activation Device Yes / No _____
(10' to 20' from hood)

Power and Fuel Shuts off when System Activated by:

 Manual Activation Device Yes / No _____

 Detector (test link) Cut Yes / No _____

Operating Instructions Posted (Next to Manual Pull) Yes / No _____

Shut off valve requires manual operation to reset Yes / No _____

Baffle Plate Required Yes / No _____

Portable Fire Extinguishers

K Class – within 30' of hood Yes / No _____

4A60BC – in path of egress Yes / No _____

Fire Alarm

Interconnected to Existing System Yes / No _____

Local Bell Yes / No _____

Certificate of completion Yes / No _____

Up Blast Fan

 Hinge Kit Installed Yes / No _____

 Flexible Conduit Installed Yes / No _____

 Grease Trap Installed Yes / No _____

 Fan discharge 40" (roof) Yes / No _____

 Ductwork 18" from roof Yes / No _____

Notes:

