

ADDENDUM No. 1

PROJECT: Spruce Street – Parrott Street Improvements
Project # 15UR03

OWNER: City of Roseburg
900 SE Douglas Ave.
Roseburg, Oregon 97470

ENGINEER: i.e. Engineering, Inc.
809 SE Pine St.
Roseburg, OR 97470

The original Contract Documents, Specifications and Plans dated April 4th, 2016, are hereby amended and supplemented by this **Addendum No. 1 dated April 29th, 2016**. All bids shall be based upon inclusion of this Addendum No. 1.

CONTRACT/BID DOCUMENTS

1) Modification – Add the following paragraph to Section 445.11 of the Special Provisions:

All storm drain pipe shall be High Density Polyethylene and comply with section 2415.10 of the standard specifications. Storm drain pipe shall have a corrugated exterior and a smooth interior, with a maximum Manning’s “n” value of 0.012. Fittings shall be soil tight.

2) Clarification – The strength of concrete noted on plans is 3300 psi. This is valid for sidewalks, curb & gutter, and retaining walls. Disregard the strength of concrete noted in Section 0C596.

3) Clarification - The footing for the retaining wall shall be poured monolithically with the sidewalk. See the typical retaining wall detail on sheet SD.2 for additional details.