

ADDENDUM No. 1
FOR
STEWART PARK PAVILION RENOVATION
PROJECT No. 19GR20

THIS ADDENDUM IS HEREBY MADE A PART OF THE ORIGINAL CONTRACT DOCUMENTS,
SPECIFICATIONS AND PLANS DATED JULY 15, 2020 TO THE SAME EXTENT AS THOUGH IT
WERE ORIGINALLY INCLUDED THEREIN.

ISSUED THIS 3RD DAY OF AUGUST 2020.

To All Solicitation Document Holders:

You are hereby notified of the following changes, deletions, additions, corrections and clarifications to the Contract Documents. All bids shall be based upon the inclusion of this Addendum No. 1.

The following formatting has been used to note additions and deletions to the contract documents.

- Deletions are formatted as stricken through (~~example~~) text.
- Changes/additions are formatted as bolded (**example**) text.

Drawing Clarification:

Drawing Sheet G010: Add the following note:

18. Lumber called for on these plans shall be sawn and surfaced dimensional limber.

Drawing Sheet S2.1: Clarification:

Wood Structural Panel note indicates all roof sheeting shall be installed with face grain perpendicular to supports. Detail on same sheet shows roof sheeting being installed with face grain parallel to supports. Roof sheet shall be installed per Wood Structural Panel notes, perpendicular to sheeting supports.

Drawing Sheet S2.1: Add the following section to the General Structural Notes:

Steel Accessories:

Steel truss plates shall be supplied with a powder coated finish. Contractor shall supply owner with color charts for selecting color and finish.

END OF ADDENDUM NO. 1


Ryan Herinckx
Project Manager
Issued July 20, 2020

Acknowledged by: _____